
# **Component Description**

# Safety Outlets Data Sheet

# **FEATURES**

• UL Listed, ULC Listed, and FM Approved for use with the systems listed in the Table , "COMPATIBILITY," on page 2

# P/N: 81-803242-000 or 82-844346-000



### **ORDER INFORMATION**

Part Number	Agent	Pressure Relief Operates At:
81-803242-000	Nitrogen/CO <sub>2</sub>	2400 to 2800 PSI (166 to 193 bar)
82-844346-000	FK-5-1-12 Agent	750 to 900 PSI (52 to 62 bar)
	HFC-227ea	

#### MATERIALS

Body and Retaining Nut: Brass Tamper Seal: Plastic



Effective: February 2018 **K-85-0506** Rev AB

### COMPATIBILITY

Series	DIOM P/N	Approvals
Kidde ECS-500™ psi with FK-5-1-12 Agent	06-237585-001	UL, ULC, FM
Kidde ECS <sup>™</sup> 360 with 3M <sup>™</sup> Novec <sup>™</sup> 1230 Fire Protection Fluid	06-236553-001	UL, ULC, FM
Kidde ADS <sup>™</sup> with 3M Novec 1230 Fire Protection Fluid	06-237256-001	UL, ULC, FM
Kidde ECS 360 Marine with 3M Novec 1230 Fire Protection Fluid	06-236559-001	UL, ULC, USCG
Kidde ADS Marine with 3M Novec 1230 Fire Protection Fluid	06-237257-001	UL, ULC, USCG
Kidde ECS 360 with HFC-227ea Agent	06-236115-001	UL, ULC, FM
Kidde Modular ECS 360 with HFC-227ea Agent	06-236116-001	UL, ULC, FM
Kidde ECS 360 Marine with HFC-227ea Agent	06-236225-001	UL, USCG
Kidde ADS Marine with HFC-227ea Agent	06-236595-001	UL, ULC, USCG
Kidde ADS with HFC-227ea Agent	06-236068-001	UL, ULC, FM
Kidde Fire Systems Marine Carbon Dioxide Version 2.4 DIOM	220610	UL, USCG
Kidde High Pressure CO <sub>2</sub>	81-CO2MAN-001	UL, ULC, FM

EXPORT INFORMATION (USA) Jurisdiction: EAR Classification: EAR99 This document contains technical data subject to the EAR.

All trademarks are the property of their respective owners.

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. believes this data to be accurate, but it is published and presented without any guarantee or warranty whatsoever. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The fire suppression system design, installation, maintenance, service and troubleshooting must be performed by trained, authorized Kidde Fire Systems distributors for the product to work correctly. If you need more information on this product, or if you have a particular problem or question, contact: KIDDE-FENWAL, INC., Ashland, MA 01721 USA, Telephone: (508) 881-2000.



2

K-85-0506 Rev AB ©2018 Kidde-Fenwal, Inc. Kidde Fire Systems 400 Main Street Ashland, MA 01721 Ph: 508.881.2000 Fax: 508.881.8920 www.kiddefiresystems.com