

Nameplate—Signs, CO2

P/N: 06-231866-85X

Effective: January 2008
K-81-9171

FEATURES

- Complies with MNBU/ANSI 2535, Standard for Environmental and Facility Safety Signs

DESCRIPTION

NFPA 12, the *Standard on Carbon Dioxide Extinguishing Systems*, requires the use of warning signs in conspicuous locations surrounding areas protected by CO2 Fire Suppression Systems. Each hazardous location has its own dedicated signage, as shown below. (See the reverse side for ordering information.)




Figure 1. Sign in Every Protected Space




Figure 4. Sign in Every Nearby Space Where Carbon Dioxide Can Accumulate to Hazardous Levels




Figure 2. Sign at Every Entrance to Protected Space




Figure 5. Sign Outside Each Entrance to Carbon Dioxide Storage Rooms




Figure 3. Sign at Every Entrance to Protected Space for Systems Provided with a Wintergreen Odorizer




Figure 6. Sign at Each Manual Actuation Station

SPECIFICATIONS:

- MATERIAL: Aluminum, .032 thick.
- SIZE: See Figure 7.
- FINISH: A clear plastic peelable cover for protection of the printed side.
- COLORS: Tri-Color: white background; orange Warning background; black characters.




Figure 7. Sign Dimensions

ORDERING INFORMATION

Part Number	Description	Figure Reference
06-231866-851	Vacate	Figure 1
06-231866-852	Do Not Enter	Figure 2
06-231866-853	Odorizer	Figure 3
06-231866-854	Migration	Figure 4
06-231866-855	Storage	Figure 5
06-231866-856	Actuation	Figure 6

This literature is provided for informational purposes only. KIDDE-FENWAL, INC. assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly. If you need more information on this product, or if you have a particular problem or question, contact KIDDE-FENWAL, INC., Ashland, MA 01721. Telephone: (508) 881-2000.



A UTC Fire & Security Company

400 Main Street
Ashland, MA 01721

Ph: 508.881.2000

Fax: 508.881.8920

www.kiddefiresystems.com