# CO<sub>2</sub> Component Description

# Odorizer Assembly, P/N: 81-897600-000

# **FEATURES**

- UL Listed
- FM Approved

## ODORIZER ASSEMBLY

The odorizer assembly injects a scent of wintergreen into the carbon dioxide during a discharge. Upon discharge, the carbon dioxide pressure ruptures a burst disc to release the scent of wintergreen. This scent warns personnel in the vicinity of the area protected by the fire suppression system that carbon dioxide gas is present. An odorizer assembly is required for each USCG (marine) CO2 system. Consult NPFA 12 (latest edition) for industrial system requirements.

#### **INSTALL ODORIZER**

Odorizer assemblies must be attached to the discharge piping in the upright position. The odorizer assembly requires approximately 9" of clearance. Odorizer assemblies connect to a 3/4" NPT fitting.



Odorizers may not be appropriate with some applications such as wet benches, food processing, or aluminum rolling mills, due to the risk of potential contamination. Always consult with the process manager prior to installing or testing an odorizer.

- 1. Install the 3/4" NPT fitting where the odorizer assembly will be located.
- 2. Screw the odorizer assembly to the 3/4" NPT fitting.




To prevent damaging the odorizer assembly during testing, it is recommended that the odorizer assembly not be installed until after system testing of the discharge piping is complete. For periodic maintenance after the system has been installed and in use, remove the odorizer assembly prior to any testing of the discharge piping.



Effective: November 2016 K-81-9161 Rev AE

#### United States Coast Guard Approved Equipment



## VERIFY ODORIZER ASSEMBLY

Every six months, verify the odorizer assembly has not discharged. Verify the odorizer assembly as follows:

- 1. Remove the odorizer assembly.
- 2. Check to make sure the burst disc is intact.
- 3. Reattach the odorizer assembly. If the burst disc has ruptured, replace the odorizer assembly.

#### POST FIRE MAINTENANCE

After a fire, replace all spent Odorizer Assemblies.

# ORDER INFORMATION

Part No.	Description
81-897600-000	Odorizer Assembly

EXPORT INFORMATION (USA) Jurisdiction: EAR

Classification: EAR99 This document contains technical data subject to the EAR.

Kidde Fire Systems

Ashland, MA 01721 USA

400 Main Street

Ph: 508.881.2000

Fax: 508.881.8920 www.kiddefiresystems.com

All trademarks are the property of their respective owners.

This literature is provided for informational purposes only. Kidde-Fenwal, Inc. assumes no responsibility for the product's suitability for a particular application. The product must be properly applied to work correctly. The technical data contained herein is limited strictly for informational purposes only. Kidde-Fenwal, Inc. believes this data to be accurate, but it is published and presented without any guarantee or warranty whatsoever. If you need more information on this product, or if you have a particular problem or question, contact Kidde-Fenwal, Inc.

©2016 Kidde-Fenwal, Inc.